

Airborne Asbestos Dust Monitoring Report

Date Monday, 28 March 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY
25-29 Whicker Road GILLMAN

DEMS Job Number 2203175

Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
Beverley Site							
1	WC	External	Northeast of small stockpile	7:09	538	2000	<0.01
2	WC	External	Northwest of small stockpile	7:10	538	2000	<0.01
3	WC	External	Southwest of small stockpile	7:12	538	2000	<0.01
4	WC	External	Southeast of small stockpile	7:13	539	2000	<0.01
Gillman Site							
5	WC	External	Concrete slab adjacent containers	8:05	515	2000	<0.01
6	WC	External	Adjacent water tap	8:07	515	2000	<0.01
7	WC	External	East of dump site	8:09	514	2000	<0.01
8	WC	External	South of dump site	8:10	515	2000	<0.01

Type: WC Working clearance monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.