

Airborne Asbestos Dust Monitoring Report

Date Friday, 20 May 2022
Removalist Old Red Brick Company
Site Address 167 William Street BEVERLEY &
DEMS Job Number 2203175
Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
			BEVERLEY				
247	B	External	Northwest of East stockpile	7:20	515	1500	<0.01
248	B	External	Northeast of East stockpile	7:22	511	1500	<0.01
249	B	External	Southeast of East stockpile	7:24	513	1500	<0.01
250	B	External	Adjacent entrance gate	7:25	513	1500	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.