



Airborne Asbestos Dust Monitoring Report

Date Friday, 22 April 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY &
25-29 Whicker Road GILLMAN

DEMS Job Number 2203175

Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
BEVERLEY							
111	B	External	Northeast of East stockpile	7:05	571	2000	<0.01
112	B	External	Northwest of East stockpile	7:06	572	2000	<0.01
113	B	External	Southeast of East stockpile	7:08	571	2000	<0.01
114	B	External	Adjacent entrance gate	7:09	566	2000	<0.01
GILLMAN							
115	B	External	Slab between south containers	6:43	612	2000	<0.01
116	B	External	South of dump site	6:44	613	2000	<0.01
117	B	External	West of dump site	6:46	613	2000	<0.01
118	B	External	North of work zone	6:47	612	2000	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.