

Airborne Asbestos Dust Monitoring Report

Date Saturday, 14 May 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY &

DEMS Job Number 2203175

Asbestos Assessor R. de Vries: AAL No. 560597

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
			BEVERLEY				
231	B	External	Northwest of East stockpile	7:47	428	1500	<0.01
232	B	External	Northeast of East stockpile	7:47	427	1500	<0.01
233	B	External	Southeast of East stockpile	7:46	427	1500	<0.01
234	B	External	Adjacent entrance gate	7:46	426	1500	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.