



Airborne Asbestos Dust Monitoring Report

Date Saturday, 21 May 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY &
25-29 Whicker Road GILLMAN

DEMS Job Number 2203175

Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
BEVERLEY							
251	B	External	Northwest of East stockpile	7:29	436	2000	<0.01
252	B	External	Northeast of East stockpile	7:31	436	2000	<0.01
253	B	External	Southeast of East stockpile	7:32	438	2000	<0.01
254	B	External	Adjacent entrance gate	7:32	439	2000	<0.01
GILLMAN							
255	B	External	Slab between south containers	7:01	489	2000	<0.01
256	B	External	Southwest of dump site	7:00	492	2000	<0.01
257	B	External	Northwest of dump site	7:03	490	2000	<0.01
258	B	External	Northeast of work zone	7:05	490	2000	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.