



Airborne Asbestos Dust Monitoring Report

Date Monday, 2 May 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY &
25-29 Whicker Road GILLMAN

DEMS Job Number 2203175

Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
BEVERLEY							
167	B	External	Northwest of East stockpile	7:10	551	2000	<0.01
168	B	External	Northeast of East stockpile	7:11	551	2000	<0.01
169	B	External	Southeast of East stockpile	7:13	551	2000	<0.01
170	B	External	Adjacent entrance gate	7:14	551	2000	<0.01
GILLMAN							
171	B	External	Slab between south containers	6:44	606	2000	<0.01
172	B	External	Southwest of dump site	6:45	607	2000	<0.01
173	B	External	Northwest of dump site	6:47	607	2000	<0.01
174	B	External	Northeast of work zone	6:48	607	2000	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.