

Airborne Asbestos Dust Monitoring Report

Date Friday, 6 May 2022

Removalist Old Red Brick Company

Site Address 167 William Street BEVERLEY &
25-29 Whicker Road GILLMAN

DEMS Job Number 2203175

Asbestos Assessor I. Langholz: AAL No. 560603

Sample Number	Type	Internal External	Sample Location	On Time h:min	Duration minutes	Ave. Flow ml/min	Dust Conc. Fibres/ml
BEVERLEY							
199	B	External	Northwest of East stockpile	7:25	516	2000	<0.01
200	B	External	Northeast of East stockpile	7:28	515	2000	<0.01
201	B	External	Southeast of East stockpile	7:30	515	2000	<0.01
202	B	External	Adjacent entrance gate	7:31	515	2000	<0.01
GILLMAN							
203	B	External	Slab between south containers	6:55	575	2000	<0.01
204	B	External	Southwest of dump site	6:57	575	2000	<0.01
205	B	External	Northwest of dump site	6:59	574	2000	<0.01
206	B	External	Northeast of work zone	6:59	576	2000	<0.01

Type: B Background monitoring

Method used: National Occupational Health and Safety Commission
Guidance Note on the Membrane Filter Method for Estimating Airborne Asbestos Dust.

Note: A dust concentration of <0.01 is the lowest reportable level permitted for the membrane filter method. All levels were well below this concentration.

Worksafe Australia exposure limit for airborne asbestos = 0.1 fibres per millilitre of air.